
**NARROMINE SHIRE COUNCIL
ORDINARY MEETING BUSINESS PAPER – 10 DECEMBER 2025
QUESTIONS WITH NOTICE REPORT**

The following Questions With Notice have been received from Cr Smith: -

1. TOWN WATER

What chemicals are added to our town water supplies?

Response from Director Infrastructure and Engineering Services

The Narromine Water Treatment Plant doses ozone gas as part of the treatment process. Following treatment, the water is chlorinated before being supplied to the distribution network. Raw bore water in Trangie is disinfected through chlorination prior to entering the distribution network. The Tomingley Water Treatment Plant applies coagulant (Alchlor) and occasionally an oxidant (potassium permanganate) during the treatment process, after which the water is chlorinated before being supplied to the distribution network. None of Council's water supply systems add fluoride.

2. EV CHARGING STATION

With regard to the EV charging station to be built in Narromine, as announced on 2DU

- (a) What involvement has NSC had in this project and for what period of time?*
- (b) Will there be a DA for this project or is it a State or Federal Government project?*
- (c) As this charging station will be located on Council owned land has a financial agreement, such as a lease, been negotiated?*
- (d) If so, what are the details?*

Response from Director Infrastructure and Engineering Services

Please see report to Council.